

Standard Schools



NAFA[®]
National Air
Filtration
Association

Recommended Practice

TRAINING
EDUCATION
CERTIFICATION

Publication Information

Why NAFA Guidelines?

The National Air Filtration Association (NAFA) provides "Best Practice Guidelines" to help supplement existing information on the control and cleaning of air through proper filtration. Many organizations recommend "minimum" air cleaning levels. NAFA publishes best practice based on the experience and expertise of our membership along with information and research of the governmental, medical and scientific communities showing the short and long term impact particulate and molecular contaminants have on human health and productivity.

This Guideline provides advice on achieving the cleanest air possible based on the design limits of existing HVAC equipment and with consideration of the impact on energy and the environment. For a more complete explanation of principles and techniques found in this Guideline, go to the website www.nafahq.org and purchase the [NAFA Guide to Air Filtration 4th Edition](#).

Copyright © National Air Filtration Association 2012

All rights reserved.

COPYRIGHT AND LIMITATIONS ON USE

The information available through NAFA® Guidelines is the property of The National Air Filtration Association® (NAFA) and is protected by copyright and other intellectual property laws. Information received through the NAFA Guidelines may be displayed, reformatted and printed for your personal, non-commercial use only. You agree not to reproduce, re-transmit, distribute, disseminate, sell, publish, broadcast or circulate the information to anyone, including but not limited to others in the same company or organization as you, without the expressed prior written consent of NAFA with the following exception:

You may, on occasion, include isolated portions of information from NAFA Guidelines in official memoranda, unit newsletters, reports, and presentations, but only if such memoranda, reports, and client presentations are distributed or otherwise made available in non-electronic form, for a non-commercial purpose to a limited number of individuals. You must include in all such memoranda, reports, and presentations the phrase, "Used with permission of The National Air Filtration Association®." You may not post any content from the NAFA Guidelines to any newsgroup, mail list, electronic bulletin board or other forum without the prior written consent of NAFA.

Disclaimer

The information contained in this Guideline is intended for reference purposes only. NAFA has used its best efforts to assure the accuracy of information and industry practice. NAFA encourages the user to work with a NAFA Certified Air Filter Specialist (CAFS), to assure that these Guidelines address specific user equipment and facility needs.

Issues regarding health information may be superseded by new developments in the field of industrial hygiene. Users are therefore advised to regard these recommendations as general guidelines and to determine whether new information is available.

NAFA does not guarantee, certify or assure the performance of any products (other than those bearing the NAFA Certified Product label), components, or systems operated in accordance with NAFA Guidelines.

**NAFA Guidelines Committee
Chair**

Trey Fly, CAFS, NCT II
Joe W. Fly Co., Inc.
3903 Warehouse Row
Austin, TX 78704
512-441-4448
Fax: 512-441-4483
trey@joeflyco.com
www.joeflyco.com

Committee Members:

Steven Brown, CAFS, NCT II
TEX-AIR Filters/
Air Relief Technologies

Shelby Calvert, CAFS
Filtration Group, Inc.

Carol Christensen, CAFS
The Filter Man, Ltd.

Larry Clark, CAFS
Clark Air Systems, Inc.

Bill Cawley, CAFS
Flanders Corporation

Kevin Delahunt, CAFS
B.G.E. Service & Supply Ltd.

Harry C. Elinsky, Jr., CAFS
Filtech, Inc.

Rupert Langston, CAFS
Air Flow Technology, Inc.

Paula Levasseur, CAFS
Cameron Great Lakes, Inc.

Stephen W. Nicholas, CAFS, NCT II
Air Industries, Inc.

Domenick Orlando, CAFS
Dave Downing & Associates

Phil Maybee, CAFS
The Filter Man, Ltd.

Bill Palmer
AeroMed, Inc.

Bill Patterson, CAFS
Dave Downing & Associates

Thomas Riddell, CAFS
Air Filter Sales & Service

Chris Zaker, CAFS, NCT
Glasfloss Industries, Inc.

Bob Williams, CAFS
Superior Fibers LLC

National Air Filtration Association®

PO Box 68639
Virginia Beach, VA 23471
757.313.7400
Fax: 757.497.1895
nafa@nafahq.org
www.nafahq.org

Filtration for Schools

Purpose.....	1
Scope	1
Background.....	1
School HVAC Systems.....	2
NAFA Best Practice Recommendations.....	2
Filter Efficiency	2
Operation and Maintenance	4
Monitoring of Flow and Pressure Drop	5
Disposal.....	5
Summary.....	5
Glossary	6
References.....	6

NAFA Guidelines for Schools

Purpose


This best practice air filtration guideline is established for the removal of particulate and molecular contaminants for the improvement of indoor air quality and protection of HVAC equipment in K-12 schools. It serves to provide the facility managers with the necessary tools to make measurable differences to the operation of the HVAC systems in their campus through air filtration.

Scope

This Guideline identifies air quality issues associated with typical schools K-12. It establishes design criteria and performance specifications for new construction, as well as existing HVAC systems. This shall include methodology for contaminant removal by filtration and associated system maintenance.

Background

School districts around the world are some of the most frequently used high traffic buildings in our society. They also hold some of our most important resources - those being students and faculty. School districts are always under financial constraints to achieve high quality education at low cost. This may result in neglect to their facilities and HVAC maintenance due to staffing, lack of knowledge and operational costs. With new research showing the benefits of cleaner environments on learning and health, our students and faculty should have cleaner air to breathe.



Sneezing, coughing and talking add condensate nuclei particles to air and increases the possibility of transmission of disease. Most public schools are funded based on student attendance and as such, excessive absenteeism potentially caused by IAQ issues may ultimately result in school districts losing funding.

While cutting small costs for proper air filtration may show an immediate savings impact on the budget, keeping up with proper preventative maintenance and scheduled air filter changes will have a more sustainable impact in the long run. Without proper maintenance and filtration, key components of HVAC systems will deteriorate, resulting in costly repairs or increase operating costs.

School HVAC Systems

Most school districts have commercial grade HVAC systems with single stage filtration. Since many of these systems are dated and have been using filters with a very low efficiency minimum efficiency reporting value (MERV) based on ANSI/ASHRAE Standard 52.2) number, it is essential to clean evaporator coils, fans, and all other major components of HVAC systems when implementing a new filtration system. Cleaning the system and installing higher efficiency/low pressure drop filters may achieve lower pressure in the system, higher airflow and higher levels of particle removal resulting in cleaner air.

NAFA Best Practice Recommendations

Based on the EPA's "Tools for Schools" program, "...all schools should have a minimum filtration efficiency of MERV 8 in all HVAC applications."

Filter Efficiency

Air filters should have Minimum Efficiency Rating* Value (MERV) of between 8 and 13.

The higher the (air filter efficiency) rating, the better the protection for the equipment and the occupants. It has been estimated that a 30% increase in static pressure across a coil results in a \$200 (electric cost) per 10,000 cfm of air movement (at 7 cents per KWH). This does not include the added cost of cleaning dirty heating or cooling oils, drain pans, or air ducts. Designers should consider specifying a low efficiency (~10%) pre-filter upstream of the main filters. The pre-filters are generally easy and inexpensive to change, and will capture a significant amount of the particulate mass in the air thereby extending the useful life of the more expensive main filters. ¹.

** Disclaimer: NAFA would like to correct a mistake made in the EPA's "Tools for Schools" document. MERV is not a Rating. It stands for Minimum Efficiency Reporting Value. It is the intention of NAFA to inform the EPA of this mistake so it can be corrected. **

NAFA recommends MERV 13 efficiency filtration for all HVAC applications in schools. Key to this efficiency is the protection for the HVAC components from particles that promote biofilm, particulate fouling, and microbial

contamination in the equipment and more importantly reducing the respirable (0.3 to 3 microns) concentration of pollutants for students and faculty. (ASHRAE Guideline 10)

It is recognized that some induction units and other room specific heating or cooling equipment may not be capable of MERV 13 filtration due to configuration or fan capacity. In these applications careful seal and selection of media filtration methods should be assessed for the protection of the HVAC component. The EPA's "Tools for Schools" program also recommends designing more filter surface area into ventilation systems.

" This has two advantages: the number of filter changes each year is reduced, thereby reducing the cost of labor to properly maintain the filters; and static pressure loss is lower, which saves money by reducing the amount of power needed to operate fans and blowers. Since different filter media are approximately proportional in their efficiency/pressure drop ratio, the most effective method for reducing pressure drop is to design more filter surface area into the filter system. This can be done by the specification of a filter with larger amounts of surface area, such as a pleated filter or bag filter. The next method is to increase the number and/or size of the filters in the airstream, for example, by mounting the filter slots in a "V" pattern, rather than a filter rack that is simply flat and perpendicular to the airstream."(2)

A proper filter should be selected and a proper change out frequency should be established. This change out frequency can vary from unit to unit within a certain building and should be established based on the following criteria:

1. The specified or allowable pressure drop
2. Filter manufacturers' recommended final pressure drop
3. Values demonstrated by experience
4. Value determined by life cycle cost analysis.

For more information about selecting the proper change out frequency, please refer to Chapter 11 of the NAFA Installation, Operations, and Maintenance of Air Filtration Systems manual.

SPECIAL APPLICATIONS – There are certain areas in schools that require more specific filtration beyond general HVAC.

Molecular Filtration: Use of molecular filtration is recommended in the following areas:

Metal working (welding fumes)
Locker Rooms

Chemistry and Biology Labs
Swimming Pool areas

Dust Separators:

Use of specialized filtration equipment such as a dust collection systems are recommended in woodworking areas.

In these special applications a NAFA Certified Air Filter Specialist (CAFS) should be contacted to determine the proper filter and /or filtration media required to remove the contaminants associated with these areas.

Operation and Maintenance

It is recommended that the manufacturer's guidelines be followed in all circumstances when retrofitting an existing system. What follows is a list of some of the more important factors to consider when operating and maintaining an HVAC air filter system. As a supplement to manufacturer's guidelines, (see NAFA Installation, Operation and Maintenance of Air Filtration Systems (IOM) manual.)

- Installation of Air Filtration Framing Systems

These systems may consist of built-up filter banks, side access housings, or modular tracks. A qualified HVAC system design engineer should be consulted to specify the required quantity, arrangement, airflow, and pressure requirements of the air filter installation.

- Installation of Filters

Refer to the manufacturer's instructions when installing filters into the HVAC system. An understanding of the entire HVAC system is helpful to ensure that the air filters are properly installed. Proper size and-gasketing is imperative to the integrity of the filter system. It is also beneficial to a maintenance program to add a filter log near the filter bank of each HVAC unit or in a computerized data base. This will help to insure that filters are changed on time and that each filter bank is using the proper change out frequency.

- System Integrity

Start Up – Maintaining the HVAC system's integrity is vital to proper air filtration. After installation, the system should be checked for:

1. Correct size of filter frames
2. Fastening devices, i.e. filter holding clips
3. Filter gaskets on frames, doors, and filters should be checked to insure that there are no leaks or gaps
4. Filter frames and housing should also be properly sealed as this will prevent air bypass and maintain system pressure.

- Maintenance

A preventative maintenance program should be in place and should include;

1. Inspection of filter frames, fastening devices, gaskets, and ductwork.

2. Removing and replacing damaged or defective gasketing and duct insulation will keep air from bypassing the filter banks.
3. Keeping the coils and blower free from dirt and debris by regular cleaning

In summary, good housekeeping will keep the HVAC system in proper working order and will provide the facility with air that is not only heated and cooled, but also clean.

Monitoring of Flow and Pressure Drop

All filters increase the resistance to the flow of air in an HVAC system. This increase is called “pressure drop” because in a draw-through system, as the filters load and the resistance increases, the fan pressure is lower on the downstream side, hence the pressure “drop” downstream of the filters. Pressure drop can be measured with a pressure sensing device or air filter gauge such as a manometer, or magnehelic.



All HVAC units should have a pressure-sensing device installed to accurately monitor the airflow and pressure drop across the filter bank. When a filter has exceeded its useful life, based on life cycle costing, it should be replaced. Leaving a filter in place after this point may increase operational and energy costs and could damage the HVAC system components.

Most molecular (gaseous removal contaminates) filters will not increase in pressure drop over time, especially with proper pre-filtration. Some particulate media when impregnated with sorbent could increase in pressure drop, however, it is not indicative of service life of the sorbent. Service life of a molecular filter is a function of types and concentration of contaminants, and filter design. Most manufacturers offer testing services to determine remaining filter service life. It is important to note that as the media life decreases, so does the efficiency of the molecular filter. Molecular filters are often recommended for change out before media is 100% spent.

Disposal

Filters should be disposed of in accordance with all local, state, and federal regulations.

Summary

There are many contributing factors involved in the degree of filtration needed in schools. These recommendations are given based on the ideal filtration to protect HVAC equipment and improve the health of students and faculty in the school system. MERV 13 filters are capable of protecting HVAC equipment and will remove target respirable particulates, which could cause illness, and should reduce overall school absenteeism.

In order to maintain the degree of filtration needed, an active maintenance program is essential. Problems arising from poor filter maintenance can cause HVAC breakdowns and a decrease in overall indoor air quality.

Glossary

Air Filter/Air Cleaning - a device used for the removal of particulate or gaseous impurities from the air.

ANSI - American National Standards Institute – As the voice of the U.S. standards and conformity assessment system, ANSI empowers its members and constituents to strengthen the U.S. marketplace position in the global economy while helping to assure the safety and health of consumers and the protection of the environment.

ASHRAE - American Society of Heating, Refrigerating and Air Conditioning Engineers. ASHRAE is an international organization that sets standards and guidelines for the heating, ventilating, air conditioning, and refrigeration industry.

CAFS - Certified Air Filter Specialist accreditation granted by NAFA® to those who pass the national exam on air filtration.

cfm - Cubic feet per minute; a volumetric measurement used to size fans and duct work.

HVAC - Heating, Ventilating & Air Conditioning

IAQ - indoor air quality describes the quality of air supplied to an interior space. The goal of IAQ is to provide air that is clean and healthy to building occupants.

Life Cycle Costing (LCC) - the investigation and valuation of the environmental impacts of air filters.

MERV - Minimum Efficiency Reporting Value refers to the lowest efficiency of a filter when tested in accordance with ANSI/ASHRAE Standard 52.2 2007.

NAFA® - registered acronym for the National Air Filtration Association, the trade association for air filter manufacturers and distributors, worldwide.


Pressure Drop - describes the drop in static pressure of the air from the upstream side of a filter to the downstream side.

References

1. U.S. Environmental Protection Agency, IAQ Design Tools for Schools, Heating, Ventilation and Air-Conditioning (HVAC) Systems <http://www.epa.gov/iaq/schooldesign/hvac.html>
2. EPA Tools for Schools Program – IAQ Design for Schools – Heating, Ventilation and Air-Conditioning Systems [http://www.epa.gov/iaq/schooldesign/hvac.html#Filter Efficiency](http://www.epa.gov/iaq/schooldesign/hvac.html#Filter_Efficiency)
3. ASHRAE Position Document on Airborne Infectious Diseases, 2009

Other NAFA Publications

NAFA Guide to Air Filtration



Air filtration is one of the most important considerations involving the design, installation and maintenance of HVAC systems, yet is one of the least understood concepts in the HVAC industry. Thus, the need for the NAFA Guide to Air Filtration, which is the most informative and comprehensive manual ever published in the HVAC Industry.

Now in its 3rd edition, the NAFA Guide to Air Filtration covers principles of air filtration, applications of all types of air filter products, filter testing methods, indoor air quality, filter owning and operating costs, plus much, much more. Over 200 pages with numerous tables, photos and illustrations help to educate the reader on the mechanics and elements of air filtration.

The NAFA Guide to Air Filtration is required reading for anyone wishing to become a NAFA Certified Air Filter Specialist. The certification examination is based on material in the manual.

It is also suggested reading for anyone involved in the design, installation, or maintenance of HVAC systems. For a copy of the NAFA Guide to Air Filtration, contact a NAFA member in your area or the NAFA home office.

Member Cost: \$49.00; Nonmember Cost: \$79.00

Installation, Operation & Maintenance of Air Filtration Systems

This manual is designed to serve as a guide for those involved in the installation, operation, and maintenance (IOM) of air filtration systems. Over 100 pages with nearly 50 illustrations highlight the universal characteristics and the important procedures involved in the IOM of air filtration systems.

Ideal for both teaching the basics to individuals just starting out in the field, as well as serving as a reference guide for experienced personnel, this manual is a must for anyone involved in the industry. The NAFA IOM Manual is required reading for the NAFA Certified Technician (NCT) program.



Member Cost: \$40.00; Nonmember Cost: \$55.00

NAFA Programs

NAFA Certified Air Filter Specialist Program



The CAFS program distinguishes those professionals who have demonstrated a thorough, up-to-date understanding of air filtration technology and a high level of professionalism.

In order to become certified, air filtration professionals must pass an extensive examination on the principles, methods and applications of air filtration, based on the text, NAFA Guide to Air Filtration. Candidates for certification are also subject to compliance with the NAFA Code of Ethics.

Certification is renewable on an annual basis pending successful completion of continued education requirements in order to demonstrate current and continued expertise.

When purchasing products or services from a Certified Air Filter Specialist, customers are assured that their particular requirements and needs will be addressed by a knowledgeable professional.

NAFA Certified Technician Level I and Level II Program

The NAFA Certified Technician Program (NCT/NCT II) is a certification program for technicians involved in the installation, operation, and maintenance of commercial air filtration systems. Originally created for NAFA members, the program has been redesigned to suit the needs of facility managers, building owners, HVAC service contractors, and those who employ technicians in the HVAC industry.



In order to certify technicians, candidates must pass an exam administered by any NAFA Certified Air Filtration Specialist (CAFS). Training sessions with a CAFS, self-study, and seminars, prepare candidates for the exam, which is an open book test with NAFA's Installation, Operation, and Maintenance of Air Filtration Systems Manual (IOM Manual).



The NCT Level II designation is earned by NCT's who attend a hands-on training of Bag in/ Bag out procedures and pass an exam administered by NAFA Staff.

Being NAFA certified provides education for individuals in the service of air filtration systems, recognizes the knowledge and expertise of technicians, and develops formalized structure for ongoing education of maintenance staff.

NAFA Product Certification



One of NAFA's latest initiatives is the development of the NAFA Product Certification Program. The program is designed to verify the performance of various air filter products as advertised by their manufacturers.

Participation by manufacturers in the program is voluntary. As the program gets underway, it is expected that most major manufacturers will submit products for certification. The public may access the NAFA website to see which products have been certified through the program.